CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 22/08/2020

Lab ID	:	CP-2021-02-17-34
Customer	:	Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Sub Division, BBMP, Bangalore.
Project Name	:	"Construction of Toilets at Govt PU Collage in Kempegowda Ward No-01 of Yelahanka Sub Division"
Agency	:	Sri. Chaitra Poornima K V (N C K Infra Tech), 4th Floor, Patel Nangegowda Layout, Kodigehalli, Sahakaranagara Bangalore-560092
Customer's Reference	:	BBMP/EE/YNK.D/EPMT-02/W.O/86/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	27-07-20
Customer ID	:	Column Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	22/08/2020

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	25/07/2020	22/08/2020	149.33 X 149.07 X 149.01	22261	8.400	610.0	27.4	27.5
2	Column Concrete	M25	25/07/2020	22/08/2020	151.72 X 151.28 X 151.82	22953	8.852	602.8	26.3	
3	Column Concrete	M25	25/07/2020	22/08/2020	150.62 X 151.16 X 150.14	22766	8.504	656.1	28.8	

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.

All information furnished by Customer/Representative

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 30 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R RUDRAPRASAD
Authorized Signatory
Technical Manager

Page 1/1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/08/2020

Lab ID	:	CP-2021-02-17-34
Customer	:	Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Sub Division, BBMP, Bangalore.
Project Name	:	"Construction of Toilets at Govt PU Collage in Kempegowda Ward No-01 of Yelahanka Sub Division"
Agency	:	Sri. Chaitra Poornima K V (N C K Infra Tech), 4th Floor, Patel Nangegowda Layout, Kodigehalli, Sahakaranagara Bangalore-560092
Customer's Reference	:	BBMP/EE/YNK.D/EPMT-02/W.O/86/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	15-07-20
Customer ID	:	PCC
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M15 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	10/08/2020

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M15	13/07/2020	10/08/2020	150.56 X 151.76 X 151.87	22848	8.302	389.1	17.0	17.3
2	PCC	M15	13/07/2020	10/08/2020	149.54 X 151.10 X 150.77	22595	8.348	397.2	17.6	
3	PCC	M15	13/07/2020	10/08/2020	151.49 X 149.16 X 151.94	22597	8.113	388.9	17.2	

A&I
A.E.E
AE

* The results obtained are satisfactory as per standard requirements.

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R RUDRAPRASAD
Authorized Signatory
Technical Manager

Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com